SIEMENS

Data sheet

6GK5204-0BA00-2BA3



SCALANCE X204IRT, managed IE IRT switch, 4x 10/100 Mbit/s RJ45 ports, Error signaling contact with set pushbutton, redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-plug optional.

product type designation	SCALANCE X204IRT
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s
interfaces / for communication / integrated	
number of electrical connections	
 for network components or terminal equipment 	4
interfaces / other	
number of electrical connections	
 for signaling contact 	1
for power supply	1
type of electrical connection	
 for signaling contact 	2-pole terminal block
 for power supply 	4-pole terminal block
design of the removable storage	
• C-PLUG	Yes
signal inputs/outputs	
operating voltage / of the signaling contacts	
at DC / rated value	24 V
operational current / of the signaling contacts	
• at DC / maximum	0.1 A
supply voltage, current consumption, power loss	
product component / connection for redundant voltage supply	Yes
type of voltage / 1 / of the supply voltage	DC
 supply voltage / 1 / rated value 	24 V
 power loss [W] / 1 / rated value 	4.8 W
 supply voltage / 1 / rated value 	18 32 V
 consumed current / 1 / maximum 	0.2 A
 type of electrical connection / 1 / for power supply 	4-pole terminal block
 product component / 1 / fusing at power supply input 	Yes
 fuse protection type / 1 / at input for supply voltage 	0.6 A / 60 V
ambient conditions	
ambient temperature	
 during operation 	-40 +70 °C
 during storage 	-40 +70 °C
during transport	-40 +70 °C
relative humidity	
 at 25 °C / without condensation / during operation / maximum 	95 %

protection class IP IP30 design, dimensions and weights compact design compact width 60 mm height 125 mm depth 124 mm net weight 0.78 kg	
designcompactwidth60 mmheight125 mmdepth124 mmnet weight0.78 kg	
width 60 mm height 125 mm depth 124 mm net weight 0.78 kg	
height125 mmdepth124 mmnet weight0.78 kg	
depth 124 mm net weight 0.78 kg	
net weight 0.78 kg	
35 mm top hat DIN rail mounting Yes	
wall mounting Yes	
S7-300 rail mounting Yes	
S7-1500 rail mounting No	
product features, product functions, product components / general	
cascading in the case of a redundant ring / at 50 reconfiguration time of <\~0.3\~s	
cascading in cases of star topology any (depending only on signal propagation time)	
product functions / management, configuration, engineering	
product function	
• CLI Yes	
web-based management Yes	
MIB support Yes	
• TRAPs via email Yes	
configuration with STEP 7 Yes	
port mirroring No	
multiport mirroring No	
with IRT / PROFINET IO switch Yes	
PROFINET IO diagnosis Yes	
PROFINET conformity class C	
network load class / according to PROFINET 2	
product function / switch-managed Yes	
protocol / is supported	
• Telnet Yes	
HTTP Yes	
HTTPS Yes TFTP Yes	
FTP Yes ROOTP No	
BOOTP No DCP Yes	
• LLDP Yes	
• SNMP v1 Yes	
• SNMP V1 Fes • SNMP v2 Yes	
• SNMP v2 • SNMP v3 Yes	
identification & maintenance function	
I&M0 - device-specific information Yes	
I&M1 – higher level designation/location designation Yes	
product functions / diagnostics	
product function	
port diagnostics Yes	
statistics Packet Size Yes	
statistics packet type Yes	
• error statistics Yes	
product functions / DHCP	
product function	
• DHCP client Yes	
product functions / redundancy	
product function	
• ring redundancy Yes	
High Speed Redundancy Protocol (HRP) Yes	
high speed redundancy protocol (HRP) with Yes	
redundancy manager	

 high speed redundancy protocol (HRP) with standby 	Yes
redundancy protocol / is supported / Media Redundancy Protocol	Yes
(MRP)	
product function	N
 media redundancy protocol (MRP) with redundancy manager 	Yes
 Parallel Redundancy Protocol (PRP)/operation in the PRP-network 	Yes
 Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA) 	No
passive listening	Yes
product functions / security	
protocol / is supported	
• SSH	Yes
product functions / time	
product function	
SICLOCK support	Yes
protocol / is supported	
• NTP	No
• SNTP	Yes
standards, specifications, approvals	
standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
 for safety / from CSA and UL 	UL 60950-1, CSA C22.2 No. 60950-1
 for emitted interference 	EN 61000-6-4:2001 (Class A)
 for interference immunity 	EN 61000-6-4:2001
MTBF	80.58 y
reference code	
 according to IEC 81346-2 	KF
 according to IEC 81346-2:2019 	KFE
standards, specifications, approvals / CE	
	Yes
certificate of suitability / CE marking	
	nents
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr	
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7)
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7)
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1	Print EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification	Print EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No No
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environer standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classificatio Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV)	nents EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No No
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No No Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL)	Enerts EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL	End EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7)
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • Lloyds Register of Shipping (LRS)	Enerts EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes No
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classificatio Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) • Polski Rejestr Statkow (PRS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classificatio Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) • Polski Rejestr Statkow (PRS) • Royal Institution of Naval Architects (RINA)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes
certificate of suitability / CE marking standards, specifications, approvals / hazardous environr standard / for hazardous zone • from CSA and UL certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 standards, specifications, approvals / marine classificatio Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) • Polski Rejestr Statkow (PRS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes E240480 (NWHP, NWHP7) EN 61000-6-4:2001 Yes Yes

further information / internet-Links	
Internet-Link	
 to web page: selection aid TIA Selection Tool 	http://www.siemens.com/tia-selection-tool
 to website: Industrial communication 	http://www.siemens.com/simatic-net
 to website: Industry Mall 	https://mall.industry.siemens.com
 to website: Information and Download Center 	http://www.siemens.com/industry/infocenter
 to website: Image database 	http://automation.siemens.com/bilddb
 to website: CAx-Download-Manager 	http://www.siemens.com/cax
 to website: Industry Online Support 	https://support.industry.siemens.com
security information	
security information	Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)
last modified:	7/8/2022 🖸