SIEMENS

Data sheet

6GK5778-1GY00-0AB0

product type designation



W778-1 M12 (USA)

IWLAN access point, SCALANCE W778-1 M12, 1 radio, 2 N-CON antenna port, iFeatures support via KEY-PLUG, IEEE 802.11a/b/g/h/n, 2.4/5GHz, gross data rate 300 Mbit/s, 2x M12 max. 100 Mbit/s, PoE integrated 2-port switch, redundant 24 V DC, M12 A-coded IP65, -30... 65°C, plug slot WPA2/802.11i/e, observe national approvals! CERT ID: MSN65-W1-M12-E2 Scope of delivery: Manuals on CD-ROM, German/English; M12 sealing caps, for operation in the USA.

transfer rate	
transfer rate	
with WLAN / maximum	300 Mbit/s
for Industrial Ethernet	10, 100 Mbit/s
transfer rate / for Industrial Ethernet	
• minimum	10 Mbit/s
• maximum	100 Mbit/s
interfaces	
number of electrical connections	
 for network components or terminal equipment 	2
for power supply	1
for redundant voltage supply	1
type of electrical connection	
 for network components or terminal equipment 	M12 interface (4-pole, D-coded), PoE
for power supply	M12 interface (4-pole, A-coded)
design of the removable storage	
• C-PLUG	Yes
• KEY-PLUG	Yes
memory	
design of the removable storage	
• C-PLUG	Yes
• KEY-PLUG	Yes
interfaces / wireless	
number of radio cards / permanently installed	1
transmission mode / for multiple input multiple output (MIMO)	2x2
number of spatial streams	2
number of electrical connections / for external antenna(s)	2
type of electrical connection / for external antenna(s)	N-Connect (socket)
product feature / external antenna can be mounted directly on device	Yes
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage	
 from Power-over-Ethernet according to IEEE802.3at for type 1 and IEEE802.3af 	48 V
consumed current	
• at DC / at 24 V / typical	0.25 A
 with Power-over-Ethernet according to IEEE802.3at 	0.125 A

for type 1 and IEEE802.3af / typical	
power loss [W]	
• at DC / at 24 V / typical	6 W
with Power-over-Ethernet according to IEEE802.3at	6 W
for type 1 and IEEE802.3af / typical	O VV
supply voltage / 1	
 from M12 Power Connector (A-coded) for redundant 	16.8 V
power supply	
supply voltage / 2	
• from M12 Power Connector (A-coded) for redundant	31.2 V
power supply	
ambient conditions	
ambient temperature	
during operation	-20 +60 °C
during storage	-40 +85 °C
 during transport 	-40 +85 °C
relative humidity / at 25 °C / without condensation / during operation / maximum	95 %
ambient condition / for operation	When used under hazardous conditions (Zone 2), the SCALANCE
·	W778-1 M12 or W738-1 M12 product must be installed in an housing with at least IP54 degree of protection according to EN 60529 within the
notestico de la ID	scope of EN 50021.
protection class IP	IP65
design, dimensions and weights	
width	140 mm
height	160 mm
depth	45 mm
width / of the enclosure / without antenna	140 mm
height / of the enclosure / without antenna	149 mm
depth / of the enclosure / without antenna	45 mm
net weight	0.95 kg
fastening method	35 mm DIN rail mounting only per accessories
S7-300 rail mounting	No
S7-1500 rail mounting	No
35 mm top hat DIN rail mounting	Yes
wall mounting	Yes
radio frequencies	
operating frequency	
for WLAN in 2.4 GHz frequency band	2.41 2.48 GHz; depending on the country approvals
• for WLAN in 5 GHz frequency band	4.9 5.8 GHz; depending on the country approvals
product features, product functions, product components	
product function / Access Point Mode	Yes
product function / client Mode	Yes
number of SSIDs	4
product function	
• iPCF Access Point	Yes; Only in combination with the 'KEY-PLUG W780 iFeatures'
• iPCF client	Yes; Only in combination with the 'KEY-PLUG W780 iFeatures' or 'KEY-PLUG W740 iFeatures'
• iPCF-MC Access Point	No
• iPCF-MC client	Yes; Only in combination with 'KEY-PLUG W780 iFeatures' or 'KEY-PLUG W740 iFeatures'
number of iPCF-capable radio modules	1
product function / iREF	Yes; Only in combination with the 'KEY-PLUG W780 iFeatures' or 'KEY-PLUG W740 iFeatures'
number of iREF-capable radio modules	1
product function / iPRP	Yes; In combination with the 'KEY-PLUG W780 iFeatures' only
product functions / management, configuration, engineer	·
number of manageable IP addresses / in client	8
product function	
CLI	Yes
	Yes
	163
web-based managementMIB support	Yes

TRAPs via email	Yes
configuration with STEP 7	Yes
 configuration with STEP 7 in the TIA Portal 	Yes
 operation with IWLAN controller 	No
 operation with Enterasys WLAN controller 	No
 forced roaming on IP down with IWLAN 	Yes
 forced roaming on link down with IWLAN 	Yes
• WDS	Yes
protocol / is supported	
Address Resolution Protocol (ARP)	Yes
• ICMP	Yes
• Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• DCP	Yes
• LLDP	Yes
	res
identification & maintenance function	Vac
I&M0 - device-specific information	Yes
I&M1 – higher level designation/location designation	Yes
product functions / diagnostics	
product function	
 PROFINET IO diagnosis 	Yes
• link check	No
 connection monitoring IP-Alive 	No
 localization via Aeroscout 	Yes
SysLog	Yes
protocol / is supported	
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
product functions / VLAN	
product function	Voc
function VLAN with IWLAN	Yes
product functions / DHCP	
product function	
DHCP client	Yes
DHCP server	Yes
 DHCP Option 82 	Yes
product functions / redundancy	
protocol / is supported	
• STP/RSTP	Yes
• MSTP	Yes
• RSTP	Yes
product functions / security	
product function	
product furfolion	
• ACL MAC bessed	Von
ACL - MAC-based Management sequests ACL IR based	Yes
 management security, ACL-IP based 	Yes
management security, ACL-IP basedIEEE 802.1x (radius)	Yes Yes
management security, ACL-IP basedIEEE 802.1x (radius)NAT/NAPT	Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i 	Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 	Yes Yes Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i 	Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 	Yes Yes Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 TKIP/AES 	Yes Yes Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 TKIP/AES protocol / is supported 	Yes Yes Yes Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 TKIP/AES protocol / is supported SSH 	Yes Yes Yes Yes Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 TKIP/AES protocol / is supported SSH RADIUS 	Yes Yes Yes Yes Yes Yes Yes Yes
 management security, ACL-IP based IEEE 802.1x (radius) NAT/NAPT access protection according to IEEE802.11i WPA/WPA2 TKIP/AES protocol / is supported SSH RADIUS product functions / time 	Yes Yes Yes Yes Yes Yes Yes Yes

- CNTD	Von
SNTP SIMATIC time synchronization (SIMATIC Time)	Yes Yes
SIMATIC time synchronization (SIMATIC Time) standards specifications approvals	100
standard, specifications, approvals	
standard • for FM	FM 3611: Class I, Division 2, Groups A,B,C,D, T4 / Class 1, Zone 2,
▼ IOI I IVI	Group IIC, T4
for safety / from CSA and UL	UL 60950-1, CSA C22.2 No. 60950-1
certificate of suitability	
EC Declaration of Conformity	Yes
CE marking	Yes
• C-Tick	Yes
• E1 approval	Yes
 railway application in accordance with EN 50155 	No
 railway application in accordance with EN 50121-4 	No
NEMA TS2	No
• IEC 61375	No
• IEC 61850-3	No
• NEMA4X	No
 Power-over-Ethernet according IEEE802.3at for type 1 and IEEE802.3af 	Yes
 Power-over-Ethernet according to IEEE802.3at for 	Yes
type 2 standard for wireless communication	
IEEE 802.11a	Yes
• IEEE 802.11a	Yes
• IEEE 802.11e	Yes
• IEEE 802.11g	Yes
• IEEE 802.11h	Yes
• IEEE 802.11i	Yes
• IEEE 802.11n	Yes
wireless approval	You will find the current list of countries at:
standards, specifications, approvals / marine classificatio	www.siemens.de/funkzulassungen
Marine classification association	
American Bureau of Shipping Europe Ltd. (ABS)	Yes
French marine classification society (BV)	Yes
DNV GL	Yes
Korean Register of Shipping (KRS)	Yes
Lloyds Register of Shipping (LRS)	Yes
Nippon Kaiji Kyokai (NK)	Yes
Polski Rejestr Statkow (PRS)	Yes
Royal Institution of Naval Architects (RINA)	Yes
	163
standards, specifications, approvals / hazardous environn	***
standards, specifications, approvals / hazardous environments	nents
standard / for hazardous zone	ents EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
standard / for hazardous zone • from CSA and UL	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div.
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/iia-selection-tool
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN • to website: Industry Mall	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/iwlan https://mall.industry.siemens.com
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN • to website: Industry Mall • to website: Information and Download Center	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/iwlan https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN • to website: Industry Mall • to website: Information and Download Center • to website: Image database	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/iwlan https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN • to website: Industry Mall • to website: Information and Download Center • to website: Image database • to website: CAx-Download-Manager	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/ida-selection-tool http://www.siemens.com/industry/infocenter http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb http://www.siemens.com/cax
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN • to website: Industry Mall • to website: Information and Download Center • to website: Image database • to website: CAx-Download-Manager • to website: Industry Online Support	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/iwlan https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb
standard / for hazardous zone • from CSA and UL certificate of suitability / CCC / for hazardous zone according to GB standard further information / internet-Links Internet-Link • to website: TIA Selection Tool • to web page: selection aid TIA Selection Tool • to the website: IWLAN • to website: Industry Mall • to website: Information and Download Center • to website: Image database • to website: CAx-Download-Manager	EN 60079-15:2005, EN 60079-0:2006, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI/ISA 12.12.01-2013, CAN/CSA C22.2 No.213-M1987, CL. 1, Div. 2, GP. A,B,C,D, T4 / CL. 1, Zone 2, GP IIC Yes http://www.siemens.com/tia-selection-tool http://www.siemens.com/tia-selection-tool http://www.siemens.com/iwlan https://mall.industry.siemens.com http://www.siemens.com/industry/infocenter http://automation.siemens.com/bilddb http://www.siemens.com/cax

functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

7/1/2021