6GK5202-2BB00-2BA3

## **Data sheet**

product type designation



SCALANCE X202-2IRT managed IE IRT switch, 2x 10/100 Mbit/s RJ45 ports, 2x 100 Mbit/s Multimode BFOC, Error signaling contact with set pushbutton, Redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-plug optional.

product type designation	SCALANCE X202-2IR1
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s
interfaces / for communication / integrated	
number of electrical connections	
<ul> <li>for network components or terminal equipment</li> </ul>	2
number of 100 Mbit/s ST(BFOC) ports	
<ul> <li>for multimode</li> </ul>	2
interfaces / other	
number of electrical connections	
<ul> <li>for signaling contact</li> </ul>	1
for power supply	1
type of electrical connection	
<ul> <li>for signaling contact</li> </ul>	2-pole terminal block
for power supply	4-pole terminal block
design of the removable storage	
• C-PLUG	Yes
signal inputs/outputs	
operating voltage / of the signaling contacts	
at DC / rated value	24 V
operational current / of the signaling contacts	
at DC / maximum	0.1 A
supply voltage, current consumption, power loss	
type of voltage / 1 / of the supply voltage	DC
<ul><li>supply voltage / 1 / rated value</li></ul>	24 V
<ul><li>power loss [W] / 1 / rated value</li></ul>	6 W
<ul><li>supply voltage / 1 / rated value</li></ul>	18 32 V
<ul><li>consumed current / 1 / maximum</li></ul>	0.3 A
<ul> <li>type of electrical connection / 1 / for power supply</li> </ul>	4-pole terminal block
<ul> <li>product component / 1 / fusing at power supply input</li> </ul>	Yes
fuse protection type / 1 / at input for supply voltage	0.6 A / 60 V
ambient conditions	
ambient temperature	
<ul> <li>during operation</li> </ul>	-40 +60 °C
<ul> <li>during storage</li> </ul>	-40 +70 °C
during transport	-40 +70 °C
relative humidity	
<ul> <li>at 25 °C / without condensation / during operation / maximum</li> </ul>	95 %

SCALANCE X202-2IRT

design, dimensions and weights  design  design  width  60 mm  height  125 mm  depth  124 mm  net weight  635 mm top hat DIN rail mounting  • S7-300 rail mounting  • S7-1500 rail mounting  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\-0.3\-s  cascading in cases of star topology  product functions / management, configuration, engineering  product function  • CLI  • web-based management  Yes  compact  c	
design compact  width 60 mm  height 125 mm  depth 124 mm  net weight 0.78 kg  fastening method  • 35 mm top hat DIN rail mounting Yes  • wall mounting Yes  • S7-300 rail mounting Yes  • S7-1500 rail mounting No  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology any (depending only on signal propagation time)  product function / management, configuration, engineering  product function  • CLI Yes	
width 60 mm  height 125 mm  depth 124 mm  net weight 0.78 kg  fastening method  ● 35 mm top hat DIN rail mounting Yes  ● wall mounting Yes  ● S7-300 rail mounting Yes  ● S7-1500 rail mounting No  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\-0.3\-s  cascading in cases of star topology any (depending only on signal propagation time)  product functions / management, configuration, engineering product function  ● CLI Yes	
height  depth  net weight  fastening method  ● 35 mm top hat DIN rail mounting  ● wall mounting  ● S7-300 rail mounting  ● S7-1500 rail mounting  Product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology  product functions / management, configuration, engineering  product function  ● CLI  124 mm  124 mm  125 mm  124 mm  127 ms  128 mm  129 ms  129 ms  120 separal  50  120 separal  50  121 separal  50  122 separal  50  123 separal  50  124 mm  125 mm  124 mm  125 mm  124 mm  125 mm  124 mm  125 mm  124 mm  124 mm  125 mm  124 mm  125 mm  124 mm  124 mm  124 mm  125 mm  124 mm	
depth  net weight  fastening method  • 35 mm top hat DIN rail mounting  • wall mounting  • S7-300 rail mounting  • S7-1500 rail mounting  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology  product functions / management, configuration, engineering  product function  • CLI  124 mm  0.78 kg  Yes  50  Yes	
net weight fastening method  • 35 mm top hat DIN rail mounting  • wall mounting  • S7-300 rail mounting  • S7-1500 rail mounting  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology  product functions / management, configuration, engineering  product function  • CLI  O.78 kg   O.78 kg  O.78 kg  O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg   O.78 kg	
fastening method  • 35 mm top hat DIN rail mounting  • wall mounting  • S7-300 rail mounting  • S7-1500 rail mounting  • S7-1500 rail mounting  No  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology  product functions / management, configuration, engineering  product function  • CLI  Yes	
■ 35 mm top hat DIN rail mounting     ■ wall mounting     ■ S7-300 rail mounting     ■ S7-300 rail mounting     ■ S7-1500 rail mounting     ■ No  Product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology  product functions / management, configuration, engineering  product function     ■ CLI  Yes	
<ul> <li>wall mounting</li> <li>\$7-300 rail mounting</li> <li>\$7-1500 rail mounting</li> <li>No</li> <li>product features, product functions, product components / general</li> <li>cascading in the case of a redundant ring / at reconfiguration time of &lt;\~0.3\~s</li> <li>cascading in cases of star topology</li> <li>product functions / management, configuration, engineering</li> <li>product function</li> <li>CLI</li> <li>Yes</li> </ul>	
S7-300 rail mounting S7-1500 rail mounting No  product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology any (depending only on signal propagation time)  product functions / management, configuration, engineering  product function  CLI  Yes	
S7-1500 rail mounting     Product features, product functions, product components / general      cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s      cascading in cases of star topology     product functions / management, configuration, engineering  product function	
product features, product functions, product components / general  cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology any (depending only on signal propagation time)  product functions / management, configuration, engineering  product function  • CLI Yes	
cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s  cascading in cases of star topology any (depending only on signal propagation time)  product functions / management, configuration, engineering  product function  • CLI  Yes	
reconfiguration time of <\~0.3\~s  cascading in cases of star topology  product functions / management, configuration, engineering  product function  • CLI  Yes	
product functions / management, configuration, engineering product function  • CLI  Yes	
product function  • CLI  Yes	
• CLI Yes	
web-based management     Yes	
MIB support     Yes	
• TRAPs via email Yes	
• configuration with STEP 7 Yes	
• port mirroring No	
• multiport mirroring No	
with IRT / PROFINET IO switch     Yes	
PROFINET IO diagnosis     Yes	
PROFINET conformity class C	
network load class / according to PROFINET 2	
product function / switch-managed Yes	
protocol / is supported	
• Telnet Yes	
• HTTP Yes	
• HTTPS Yes	
• TFTP Yes	
• FTP Yes	
• BOOTP No	
• DCP Yes	
• LLDP Yes	
• SNMP v1 Yes	
• SNMP v2 Yes	
• SNMP v3 Yes	
identification & maintenance function	
• I&M0 - device-specific information Yes	
• I&M1 – higher level designation/location designation Yes	
product functions / diagnostics	
product function	
• port diagnostics Yes	
• statistics Packet Size Yes	
• statistics packet type Yes	
• error statistics Yes	
product functions / DHCP	
product function	
DHCP client     Yes	
product functions / redundancy	
product function	
• ring redundancy Yes	
High Speed Redundancy Protocol (HRP)     Yes	
• high speed redundancy protocol (HRP) with  Yes	
redundancy manager	

<ul> <li>high speed redundancy protocol (HRP) with standby redundancy</li> </ul>	Yes
protocol / is supported / Media Redundancy Protocol (MRP)	Yes
product function	
<ul> <li>media redundancy protocol (MRP) with redundancy manager</li> </ul>	Yes
<ul> <li>Parallel Redundancy Protocol (PRP)/operation in the PRP-network</li> </ul>	Yes
<ul> <li>Parallel Redundancy Protocol (PRP)/Redundant Network Access (RNA)</li> </ul>	No
passive listening	Yes
product functions / security	
protocol / is supported	
• SSH	Yes
product functions / time	
product function	Voc
SICLOCK support  Tracked / is supported.	Yes
protocol / is supported	Na
• NTP	No
• SNTP	Yes
standards, specifications, approvals	
standard	
● for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
<ul> <li>for safety / from CSA and UL</li> </ul>	UL 60950-1, CSA C22.2 No. 60950-1
<ul> <li>for emitted interference</li> </ul>	EN 61000-6-4:2001 (Class A)
<ul> <li>for interference immunity</li> </ul>	EN 61000-6-4:2001
MTBF	70.9 y
reference code	
<ul> <li>according to IEC 81346-2</li> </ul>	KF
<ul> <li>according to IEC 81346-2:2019</li> </ul>	KFE
standards, specifications, approvals / CE	Yes
standards, specifications, approvals / CE certificate of suitability / CE marking	Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm	Yes nents
standards, specifications, approvals / CE certificate of suitability / CE marking	Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone  • from CSA and UL	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone  • from CSA and UL certificate of suitability	Yes nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone  • from CSA and UL	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes
standards, specifications, approvals / CE  certificate of suitability / CE marking  standards, specifications, approvals / hazardous environe standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.	Yes nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr. standards, specifications, approvals / other	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other certificate of suitability	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other certificate of suitability • C-Tick	Yes nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes
standards, specifications, approvals / CE  certificate of suitability / CE marking  standards, specifications, approvals / hazardous environn  standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard  • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability  • C-Tick  • KC approval	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environn standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other certificate of suitability  • C-Tick • KC approval • railway application in accordance with EN 50155	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification Marine classification association	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification Marine classification association	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No  No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability  • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classificatio  Marine classification association • American Bureau of Shipping Europe Ltd. (ABS)	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No  No  No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environe standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classificatio  Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV)	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No  No  No  Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV)	Yes nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No No
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL)	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No  No  No  No  No  No  No  No  No  N
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environm standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS)	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No  No  No  Yes  Yes  Yes  No  No  No  Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environe standard / for hazardous zone  • from CSA and UL  certificate of suitability • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK)	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No No Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environment standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard  • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability  • C-Tick  • KC approval  • railway application in accordance with EN 50155  • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association  • American Bureau of Shipping Europe Ltd. (ABS)  • French marine classification society (BV)  • Det Norske Veritas (DNV)  • Germanische Lloyd (GL)  • DNV GL  • Lloyds Register of Shipping (LRS)  • Nippon Kaiji Kyokai (NK)  • Polski Rejestr Statkow (PRS)	Yes  nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes  E240480 (NWHP, NWHP7)  EN 61000-6-4:2001  Yes  Yes  No  No  No  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environment standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability  • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association  • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) • Polski Rejestr Statkow (PRS) • Royal Institution of Naval Architects (RINA)	Yes nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No No Yes
standards, specifications, approvals / CE certificate of suitability / CE marking standards, specifications, approvals / hazardous environment standard / for hazardous zone  • from CSA and UL  certificate of suitability  • CCC / for hazardous zone according to GB standard  • for cULus HazLoc / as File Nr.  standards, specifications, approvals / other  certificate of suitability  • C-Tick  • KC approval  • railway application in accordance with EN 50155  • railway application in accordance with EN 50124-1  standards, specifications, approvals / marine classification  Marine classification association  • American Bureau of Shipping Europe Ltd. (ABS)  • French marine classification society (BV)  • Det Norske Veritas (DNV)  • Germanische Lloyd (GL)  • DNV GL  • Lloyds Register of Shipping (LRS)  • Nippon Kaiji Kyokai (NK)  • Polski Rejestr Statkow (PRS)	Yes nents  EN 60079-0: 2006, EN60079-15: 2005, II 3 (2) G Ex nA [op is] IIC T4, KEMA 07 ATEX 0145 X  ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4  Yes E240480 (NWHP, NWHP7)  EN 61000-6-4:2001 Yes Yes No No No Yes

## further information / internet-Links

## Internet-Link

• to web page: selection aid TIA Selection Tool

• to website: Industrial communication

• to website: Industry Mall

• to website: Information and Download Center

• to website: Image database

• to website: CAx-Download-Manager

• to website: Industry Online Support

http://www.siemens.com/tia-selection-tool

http://www.siemens.com/simatic-net

https://mall.industry.siemens.com

http://www.siemens.com/industry/infocenter

http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

## security information

security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

5/11/2022